

# PG&E ROCK CREEK SWITCHING CENTER

## Morning Report

Sent by AutoSend on Jul 14 2021 6:00AM PPT

Log Date Time	Unit	ID/Location	Workflow	Description	Created By
07/13/2021 07:06:48	ROCK CREEK SWITCHING CENTER	GRIZZLY PH	General Log	TCB CREW IN STATION	[REDACTED]
07/13/2021 06:48:00	ROCK CREEK SWITCHING CENTER	CRESTA DAM	General Log	RECEIVED AC AND DC POWER FAIL ALARMS. STAND-BY GEN RUNNING. LINCICUM NTFD AND RESPONDING.	[REDACTED]
07/13/2021 07:24:14	ROCK CREEK SWITCHING CENTER	ROCK CREEK PH	General Log	ALLIED CRANE IN STATION FOR TAILRACE CRANE WORK.	[REDACTED]
07/13/2021 08:52:42	ROCK CREEK SWITCHING CENTER	CRESTA DAM	General Log	[REDACTED] REPORTS THE BUCKS 1101 IS OUT. LIGHTS OUT IN TUNNEL AS WELL AS CRESTA DAM STA SERV.	[REDACTED]
07/13/2021 09:04:50	ROCK CREEK SWITCHING CENTER	BUCKS CREEK PH	General Log	[REDACTED] RPTS BUCKS 1101 SUPPLYING STA SERV TO PH.	[REDACTED]
07/13/2021 09:11:05	ROCK CREEK SWITCHING CENTER	NORTH VALLEY DO	General Log	NTFD NVDO [REDACTED] OF ITEMS 0852 AND 0904. WILL SEND T-MEN TO PATROLL 1101 FROM SUB TO CRESTA DAM.	[REDACTED]
07/13/2021 11:54:00	ROCK CREEK SWITCHING CENTER	GRIZZLY PH	General Log	TCB CREW OUT OF STATION	[REDACTED]
07/13/2021 13:33:34	ROCK CREEK SWITCHING CENTER	POE DAM	General Log	[REDACTED] RPTS THERE WILL BE NO CORRECTED FLOW FOR NF-23. ADJUSTED FLOW SETPOINT FROM 320CFS TO 340CFS TO GET OUT OF ALARM.	[REDACTED]
07/13/2021 15:04:38	ROCK CREEK SWITCHING CENTER	NF	General Log	NF-51 [REDACTED] IN STA WORKING ON ENCODER ISSUE	[REDACTED]
07/13/2021 16:03:47	ROCK CREEK	NF	General Log	NF-51 [REDACTED] LEFT STA	[REDACTED]

07/13/2021	17:01:31	ROCK CREEK SWITCHING CENTER	FIELD	General Log	RECEIVED RADIO CALL FIRE NORTH OF CRESTA DAM ON THE HILLSIDE
07/13/2021	17:06:06	ROCK CREEK SWITCHING CENTER	ROCK CREEK PH	General Log	NTFD CAL FIRE OF ITEM 1701
07/13/2021	17:33:36	ROCK CREEK SWITCHING CENTER	BUCKS CREEK PH	General Log	██████████ AND CREW OUT OF STATION
07/13/2021	19:09:18	ROCK CREEK SWITCHING CENTER	FIELD	General Log	RECIEVED CALL FROM ██████████ AT HAZARD COMMUNICATION AWARENESS CENTER. SHE RPTS THAT FIRE REPORTED NEAR CRESTA DAM (LOG ITEM 17:01) IS APPROXIMATELY 2 ACRES AT THIS TIME. CAL FIRE HAS DEPLOYED RETARDANT ON 2 SIDES AND THAT TANKER IS CONTINUING TO FLY. SIPT ENGINE ON SITE BUT CANNOT DRIVE TO SCENE DUE TO TERRAIN. SHE IS NOT AWARE OF ANY NEED TO DE-ENERGIZE TRANSMISSION LINES AT THIS TIME. SHE STATED WE CAN CALL ██████████ UNTIL 2030 WITH ANY FURTHER QUESTIONS.
07/13/2021	19:01:20	ROCK CREEK SWITCHING CENTER	ROCK CREEK PH	Trouble	RECIEVED #1GOV NON CRITICAL ALARM, AT HMI FOUND #2 LEAKAGE PUMP BREAKER TRIPPED ALARM HAD COME IN MOMENTARILY AND CLEARED. ALARM RESET OK
07/13/2021	19:31:56	ROCK CREEK SWITCHING CENTER	NORTH VALLEY DO	Trouble	CALLED NVDO ██████████ TO FOLLOWUP ON LOSS OF AC AT CRESTA DAM (LOG ITEM 09:11) HE RPTS THAT T-MEN ARE ENROUTE TO OPEN SW941 PER CAL FIRE REQUEST. THIS WILL LEAVE CRESTA DAM WITHOUT AC POWER AT THIS TIME. STANDBY GEN STILL RUNNING
07/13/2021	19:23:00	ROCK CREEK SWITCHING CENTER	GCC	General Log	NTFD GCC ██████████ OF LOG ITEM 19:09
07/13/2021	21:18:19	ROCK CREEK SWITCHING CENTER	GCC	General Log	GCC ██████████ CALL AND REQUESTS ANY UPDATES ON THE FIRE NEAR CRESTA DAM, NTFD HIM OF LOG ITEM 19:31

NF

07/13/2021	ROCK 21:00:00	CREEK SWITCHING CENTER		General Log	RECEIVED NF 57 OVER FERC LIMIT TWICE ALARM, FLOWS ALREADY ABOVE 200CFS
07/13/2021	ROCK 22:21:30	CREEK SWITCHING CENTER	GCC	General Log	GCC [REDACTED] RPTS HE RECIEVED WORD FROM TLINE SUPERVISOR [REDACTED] THAT THE FIRE NEAR CRESTA DAM IS CONTAINED AND THERE IS NO THREAT TO PGE EQUIPMENT AT THIS TIME  IN ANTICIPATION OF #1 UNIT LOAD CHANGE TO 0MW AT 2400 CHECKED SEAL WATER FLOW, FOUND LOWER SEAL WATER AT 27GPM (25GPM IS TRIP POINT), PLACED UNIT IN MANUAL, CYCLED LOWER SEAL WATER ISOLATION VLV 20 TIMES AND FLOW INCREASED TO 46GPM. PLACED UNIT BACK IN LOCAL AUTO
07/13/2021	ROCK 23:43:13	CREEK SWITCHING CENTER	ROCK CREEK PH	General Log	(25GPM IS TRIP POINT), PLACED UNIT IN MANUAL, CYCLED LOWER SEAL WATER ISOLATION VLV 20 TIMES AND FLOW INCREASED TO 46GPM. PLACED UNIT BACK IN LOCAL AUTO
07/14/2021	ROCK 00:00:26	CREEK SWITCHING CENTER	NF	General Log	RECEIVED NF 56 OVER FERC LIMIT TWICE ALARM, FLOWS ALREADY ABOVE 200CFS
07/14/2021	ROCK 00:04:45	CREEK SWITCHING CENTER	ROCK CREEK PH	General Log	#1 UNIT TO 0MW PER LOAD SCHEDULE
07/14/2021	ROCK 01:03:10	CREEK SWITCHING CENTER	ROCK CREEK PH	Trouble	RECIEVED TRANSFORMER BANK NO.1 GAS PRESSURE LOW ALARM
07/14/2021	ROCK 05:03:28	CREEK SWITCHING CENTER	ROCK CREEK PH	Station Conditions	STATION CONDITIONS: BUCKS CREEK UNIT #1 RESERVE S/D BUCKS CREEK UNIT #2 SEP FOR ANNUAL CRESTA UNIT #1 PARA CRESTA UNIT #2 PARA GRIZZLY ROLLING PROVIDING STA SERVICE. POE UNIT #1 PARA POE UNIT #2 PARA ROCK CREEK UNIT #1 PARA. ROCK CREEK UNIT #2 PARA SUMP #3 PUMP TRIP TCO C/O FOR OIL DETECTION DUE TO ALARM MALFUNCTION. BUCKS VLV 3 CLOSED IN AUTO BUCKS VLV 4 CLOSED IN AUTO TOADTOWN PARA AND BLOCK LOADED DESABLA PARA AND BLOCK LOADED LIME SADDLE UNIT #1 SEP LACK OF WATER LIME SADDLE UNIT #2 SEP LACK OF WATER UPPER CENTERVILLE CANAL IN SERVICE LOWER CENTERVILLE CANAL CLEARED INDEFINITELY BUTTE CANAL IN SERVICE HENDRICKS CANAL IN SERVICE MIDDLE MIOCENE CANAL IN SERVICE

07/14/2021 ROCK      ROCK      General      WEATHER: SUNSHINE AND HOT  
05:05:57 CREEK      CREEK PH Log  
SWITCHING  
CENTER

